

Double Row Terminal Blocks

Kulka® 604 GP Series

600 Volts AC/DC (Classes B/C)

Class D does not apply



604 GP 04

Specifications:

- Base, General Purpose Phenolic, 150°C
- Open Back Design (Insulator Strip required for Voltage Rating - see page 108)
- JJ (GDI-30F) Material Available
- Screws, #12-32 Binder Head, Phil-Slot, Brass
- Terminals, Plated Brass
- 1-8 Poles
- 7/8" Centers
- Wire Range With Wire Binding Screw #10 - #12 AWG – 30 Amps
- 70 Amps with Listed Wire Lugs
- UL Recognized File No. XCFR2.E47811
- CSA Certified File No. LR19766
- **CE**
- RoHS Compliant

Kulka® Catalog #	# of poles	Dimensions	
		A	B
604 GP 01 PSB	1	2.28	1.75
604 GP 02 PSB	2	3.16	2.63
604 GP 03 PSB	3	4.03	3.50
604 GP 04 PSB	4	4.91	4.38
604 GP 05 PSB	5	5.78	5.25
604 GP 06 PSB	6	6.66	6.13
604 GP 07 PSB	7	7.53	7.00
604 GP 08 PSB	8	8.41	7.88

mm=dim X 25.4

For electronic drawings or 2D/3D CAD data,
send request to drawings@marathonsp.com

Hardware Options:

(Hardware options may affect ratings - consult Customer Service)

CATALOG #	PRODUCT DESCRIPTION	PAGE REFERENCE
MSP	KULKA	
J 604	Line to Line Jumper	See Page 102
2402	Stud 10-32 Brass (.43 H) Nuts included	See Page 105

See pages 100-111 for terminal block accessories

