# E2C/E2C-H

CSM\_E2C\_E2C-H\_DS\_E\_9\_7

# Separate Amplifier Sensor with Sensitivity Adjustment

- · Compact design with smaller Sensor Head.
- Heat-resistance model available for application between –10 and 200°C.





Be sure to read *Safety Precautions* on page 15.

# **Ordering Information**

#### Sensors [Refer to Dimensions on page 18.]

**Standard Models** 

	Sensor					,	Amplifier Ur	nits	
Appeara	nce	Stable sensin	ıg area *	Model	Combination	Model	Power supply/	Timer func- tion	Self-diag- nostic output
	3.5 dia.	0.8 (1.8) mm		E2C-CR8A 3M	_	E2C-GE4A	DC/ (NPN)		
	3.8 dia.	0.8 (1.8) mm		E2C-CR8B 3M			(141 14)		
	M5	1 (2) mm		E2C-X1A 3M		E2C-GF4A	DC/ (PNP)		
Shielded	5.4 dia.	1 (2) mm		E2C-C1A 3M			DC/		
	M8	1.5 (3) mm		E2C-X1R5A 3M		E2C-JC4AP 2M *	(NPN)	Yes	Yes
	M12	2 (5) mm		E2C-X2A 3M		E2C-JC4A 2M	DC/ (NPN)	Yes	
	M18	5 (10) mm		E2C-X5A 3M			(141 14)		
	M30	10 (18)	mm	E2C-X10A 3M		E2C-AM4A	DC/(NPN)		
Unshielded	40 dia.		20 (50) mm	E2C-C20MA 3M		E2C-AK4A	AC		

<sup>\*1.</sup> Values in parentheses are for the maximum sensing distances at 23°C.

## **Heat-resistant Model**

		Sensor	Combination	Amplifier Unit		
Appea	rance	Stable sensing area	а	Model	Combination	Model
Objection	M8	1.5 mm		E2C-X1R5AH 3M	E2C	-JC4CH 2M
Shielded	M12	2 mm		E2C-X2AH 3M	E2C	-JC4DH 2M
	M18	5 mm		E2C-X5AH 3M	■ E2C	-JC4EH 2M

Note: Characteristics will change if the cable length changes. Do not cut or extend the cable.

<sup>\*</sup> Self-diagnostic output, timer, and DIN Track mounting.

## **Accessories (Order Separately)**

Mounting Brackets A Mounting Bracket is not provided with the Sensor. Order a Mounting Bracket separately if required. [Refer to Dimension on page 21.]

Name	Model	Applicable Sensors	Remarks
Mounting Brackets	Y92E-F3R5	E2C-CR8A, for 3.5 dia.	
Mounting Brackets	<b>Y92E-F5R4</b> E2C-C1A, for 5.4 dia.		

Connection Sockets A Socket is not provided with the Amplifier Unit. Order a Socket separately if required. [Refer to Dimension on page 21.]

Name	Model	Applicable Amplifier Unit	Remarks
Front Connection Sockets	PYFZ-08	E2C-GE4A E2C-GF4A	Hold-down Clips (Order Separately) PYC-A1 Sold as a set.
	P2CF-08	E2C-AM4A	
	P2CF-11	E2C-AK4A	
	P3G-08	E2C-AM4A	
Back Connection Sockets	P3GA-11	E2C-AK4A	
Back Connection Sockets	PY08	E2C-GE4A E2C-GF4A	

Nut Sets A Nut Set is included with the Sensor. Order a Nut Set when required, e.g., if you lose the nuts.

Model	Applicable Sensors	Applicable Sensor diameter	Set contents
Y92E-NWM05	E2C-X1A	M5	Clamping nuts (brass with nickel plating): 2 Toothed washer (iron with zinc plating): 2

Adapters An Adapter is not provided with the Amplifier Unit. Order an Adapter separately if required. [Refer to Dimension on page 21.]

Name	Model	Applicable Amplifier Unit	Remarks
	Y92F-30		
Embedded Adapters	Y92F-70	E2C-AM4A/-AK4A	
	Y92F-71		

For details on Mounting Brackets, Protective Covers, and Sputter Protective Covers, refer to Accessories on Y92 ...

# **Ratings and Specifications**

#### **Standard Models**

#### Sensors

Item	Model	E2C-CR8A/ -CR8B	E2C-X1A/ -C1A	E2C-X1R5A	E2C-X2A	E2C-X5A	E2C-X10A	E2C-C20MA		
Sensing	distance (at 23°C)	1.8 mm	2 mm	3 mm	5 mm	10 mm	18 mm	50 mm		
Stable sensing	Ambient temperature	0 to 0.8 mm	0 to 1 mm	0 to 1.5 mm	0 to 2 mm	0 to 5 mm	0 to 10 mm	0 to 20 mm		
area	At 0 to 40°C	0 to 1.2 mm	0 to 1.5 mm	0 to 2 mm	0 to 2.5 mm	0 to 7 mm	0 to 15 mm	0 to 28 mm		
Different	tial travel	Refer to Ratings and Specifications on page 4 for Amplifier Unit specifications.								
Detectab	ole object	Ferrous metal (	The sensing dista	ance decreases v	vith non-ferrous r	netal. Refer to <i>Ei</i>	ngineering Data o	on page 7.)		
Standard ject	d sensing ob-	Iron, $5 \times 5 \times 1$ n	nm	Iron, 8 × 8 × 1 mm	Iron, 12 × 12 × 1 mm	Iron, 18 × 18 × 1 mm	Iron, 30 × 30 × 1 mm	Iron, 50 × 50 × 1 mm		
Respons frequence		1 kHz		800 Hz		350 Hz	100 Hz	50 Hz		
Ambient temperat	ture range	Operating/Stora	ge: –25 to 70°C	(with no icing or	condensation)					
Ambient humidity		Operating/Stora	ge: 35% to 95%	(with no condens	sation)					
Tempera influence		15% max. of se	nsing distance at	23°C in the temp	perature range of	-25 to 70°C				
Vibration	n resistance	Destruction: 10	to 55 Hz, 1.5-mn	n double amplitud	de for 2 hours eac	ch in X and Y dire	ections			
Shock re	esistance	Destruction: 500	0 m/s² 3 times ea	ch in X and Y dir	ections					
Degree o	of protection	IEC 60529 IP67	, in-house stand	ards: oil-resistant						
Connect	ion method *2	Pre-wired Mode	ls							
Connect	ion method 2	High-frequency	coaxial cable (St	andard cable len	gth: 3 m)					
Weight (packed	state)	Approx. 40 g	Approx. 45 g	Approx. 50 g	Approx. 60 g	Approx. 140 g	Approx. 270 g	Approx. 300 g		
	Case	Stainless steel	Brass							
	Sensing surface	ABS resin								
Materi- als	Cable	Vinyl chloride (F	PVC)				Polyethylene (P	E)		
	Clamping nut		Brass, nickel-pl	ated (except E20	C-C1A)					
	Toothed washer		Iron, zinc-plated	d (except E2C-C1	A)					
Accesso	ries		1							

<sup>\*1.</sup> The minimum value when using the solid-state control output on the Amplifier Unit.

Measurement conditions are as follows: standard sensing object, a distance of twice the standard sensing object, and a set distance of half the sensing distance.

\*2. Refer to 6 for cable lengths when combining Amplifier Units and Sensors.

The characteristic impedance of the high-frequency coaxial cable is 50 Ω.

## **Amplifier Units**

Item	Model	E2C-GE4A	E2C-GF4A	E2C-JC4A E2C-JC4AP	E2C-AM4A	E2C-AK4A
Power sup age (operage age range	ating volt-	12 to 24 VDC (10 to 30 VD	C), ripple (p-p): 10% max. *1			100 to 240 VAC (90 to 264 VAC) 50/60 Hz
Current	tion	25 mA max.		45 mA max.	50 mA max.	55 mA max.
Sensing d	listance nt range *2	20% min. of rated sensing ometer	distance with 4-turn potenti-	20% to 100% of rated sens	ing distance with 4-turn pote	entiometer
Differentia adjustmen	al travel	Differential travel fixed (10°	% max. of sensing distance)		1% to 5% of rated sensing	distance
Re-	Solid- state	(Refer to the response freq	uency of the Proximity Sens	or.)		
sponse time	Relay		-			20 ms max.
Control outputs	Solid- state	NPN Load resistance: 4.7 kΩ, 100 mA max. (30 VDC max.) (Residual voltage: 1.5 V max.)	PNP Load resistance: 4.7 kΩ, 100 mA max. (30 VDC max.) (Residual voltage: 1.5 V max.)	NPN Open-collector output 100 mA max. (30 VDC max.) (Residual voltage: 0.7 V max.) (E2C-JC4AP: 1 V max.)	NPN/PNP output Open-collector output 200 mA max. (30 VDC max.) (Residual voltage: 1.5 V max.)	Transistor/photocoupler 50 mA max. (40 VDC max.) (Residual voltage: 2 V max.)
	Relay		-			Relay output, SPDT 2 A at 250 VAC, cosφ = 1 (resistive load) *3
			Detection indicator (red) (C Stability indicator (green) (			
Operation	mode	Changed with NO/NC switch	ch.			
Self-diagr output	nostic	-		(E2C-JC4AP only) Output transistor turns ON when Sensor open circuit or unstable sensing is de- tected; solid-state NPN open-collector 50 mA max. (30 VDC max.) (Residual voltage: 1 V max.)	-	<del></del>
Timer fun	ction	-	-	OFF-delay: 40 ±10 ms	-	
Cable leng compensa between S Amplifier	ation Sensor and	-		(E2C-JC4AP only) 3 m/5 m, terminals Short-plate switching Shorted: 1 to 3 m Open: 3 to 5 m	Mode switched with 4-posi	tion switch.
Ambient temperatu	ure range	Operating/storage: -10 to 5	55°C (with no icing or conder	nsation)		
Ambient humidity	range	Operating/Storage: 35% to	85% (E2C-JC4AP: 35% to 9	95%) (with no condensation)		
Temperat influence		10% max. of sensing distar	nce at 23°C in the temperatu	re range of –10 to 55°C		
Voltage in	nfluence			age in the rated voltage $\pm 20^{\circ}$		
Insulation			etween current-carrying par			
Dielectric	strength	DC Models: 1,000 VAC, 50 AC Models: 1,500 VAC, 50	/60 Hz for 1 min between cu /60 Hz for 1 min between cu	rrent-carrying parts and case	e e	
Vibration	resistance		mm double amplitude for 2	Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions		-mm double amplitude for 2 directions

<sup>\*1.</sup> A full-wave rectification power supply of 24 VDC ±10% (average value) can be used (except for the E2C-GE4□).
\*2. The sensing distance range required to maintain performed is given for using the Amplifier Unit in combination with the Sensor.
\*3. Internal relay: G2R-14 DC 12V

Model	E2C-GE4A	E2C-GF4A	E2C-JC4A	E2C-AM4A	E2C-AK4A	
Item		220-01-4A	E2C-JC4AP	LZO-AM-A	LEO-ANTA	
Shock resistance	Destruction: 100 m/s <sup>2</sup> 3 tim	es each in X, Y, and Z direc	tions			
Life expectancy		Mechanical: 1: operations mir Electrical: 100 operations mir				
Connection method	Terminal block		Pre-wired Models (Standard cable length: 2 m)	Terminal block		
Weight (packed state) *4	Approx. 20 g		E2C-JC4A: Approx. 50 g E2C-JC4AP: Approx 80 g	Approx. 140 g	Approx. 250 g	
Accessories	Instruction manual		Caution labels, Mounting Bracket (E2C-JC4A: M3 × 15 Phillips mounting screw), instruction manual	Instruction manual		

<sup>\*4.</sup> The weight of the Connection Socket is not included.

## **Heat-resistant Models**

#### Sensors

Senso							
Item	Model	E2C-X1R5AH	E2C-X2AH	E2C-X5AH			
Detect	able object	Ferrous metal (The sensing distance decreases with non-ferrous metal, refer to <i>Engineering Data</i> on page 7.)					
Standa object	rd sensing	Iron, 8 × 8 × 1 mm	Iron, 12 × 12 × 1 mm	Iron, 18 × 18 × 1 mm			
Stable area	sensing	0 to 1.5 mm	0 to 2 mm	0 to 5 mm			
Differe	ntial travel	0.04 mm max.		0.1 mm max.			
Respo		300 Hz					
	Ambient temperature range Operating/Storage: -10 to 200°C (with no icing or densation)						
Ambie humidi	nt ity range	Operating/Storage: 35% to 95% (with no condensation)					
	Temperature influence ±0.2%/°C						
Vibrati resista			55 Hz, 1.5-mm do , Y, and Z direction				
Shock	resistance	Destruction: 500 r tions	n/s <sup>2</sup> 3 times each ir	X, Y, and Z direc-			
Degree		IEC 60529 IP60 *:	2				
Conne	ction meth-	Pre-wired Models Heat-resistant, hig	(Cable length: 3 mgh-frequency coaxi	) al cable			
Weight (packe	t d state)	Approx. 50 g	Approx. 60 g	Approx. 140 g			
	Case	Brass					
	Sensing surface	PEEK (polyether e	ether ketone)				
Mate-	Cable	Fluorine resin					
rials	Clamping nut	Brass, nickel-plate	ed				
	Toothed washer	Iron, zinc-plated					

Note: Ratings and characteristic are given for 50% of the stable sensing area.

\*1. Measurement conditions are as follows: standard sensing object, a distance of twice the standard sensing object, and a set distance of half the sensing

## Amplifier Units

Ampii	tier Units							
Item	Model	E2C-JC4CH	E2C-JC4DH	E2C-JC4EH				
voltage	ting voltage	12 to 24 VDC (10 to 30 VDC), ripple (p-p): 10% max.						
Currention	it consump-	45 mA max.						
	ng distance ment range	20% to 100% of ra 4-turn potentiome	ated sensing distand ter	се				
Con- trol	Load current	NPN open collecto	or, 100 mA max. (30	) VDC max.)				
out- puts	Residual voltage	0.8 V max.						
Indicat	tors	Detection indicato	r (red)					
Operat	ion mode	Changed with NO	/NC switch.					
Cable compe	length ensation	Switched between	Switched between 3 and 5 m.					
Ambie ture ra	nt tempera- nge	Operating/storage: –10 to 55°C (with no icing or condensation)						
Ambie humidi	nt ity range	Operating/storage: 35% to 85% (with no condensation)						
Tempe		±0.08%/°C						
Voltage	e influence	$\pm 2\%$ max. of sensing distance at rated voltage in the rated voltage $\pm 20\%$ range						
Insulat resista		$50~M\Omega$ min. (at 500 VDC) between current-carrying parts and case						
Dielect		1,000 VAC, 50/60 Hz for 1 min between current-carrying parts and case						
Vibrati resista		Destruction: 10 to 2 hours each in X	55 Hz, 1.5-mm dou Y, and Z directions	ble amplitude for				
Shock	resistance	Destruction: 100 m/s² 3 times each in X, Y, and Z directions						
Degree		IEC 60529 IP20						
Conne		Pre-wired Models (Cable length: 2 m)						
Weight state)	t (packed	Approx. 80 g						
Access	sories	Caution labels, Mo	ounting Bracket, ins	truction manual				

<sup>\*1.</sup> A full-wave rectification power supply of 24 VDC  $\pm 10\%$  (average value) can

<sup>\*2.</sup> Do not operate the Sensor in areas exposed to water vapor because the enclosure is not waterproof.

<sup>be used.
\*2. The sensing distance range required to maintain performed is given for using the Amplifier Unit in combination with the Sensor.</sup> 

# **Cable Lengths for Sensor-Amplifier Unit Combinations**

#### **Standard Models**

Sensor Amplifier Units	E2C-CR8A	E2C-CR8B	E2C-X1A	E2C-C1A	E2C- X1R5A	E2C-X2A	E2C-X5A	E2C-X10A	E2C- C20MA
E2C-GE4A		D,	estricted to 3	m					
E2C-GF4A		ixe	estricted to 5	111.					
E2C-JC4AP		1 to 3 m: Short cable length terminals * 3 to 5 m: Open cable length terminals *							
E2C-JC4A			Restricte	ed to 3 m.					
E2C-AM4A	S	et cable lengt	0 to 5 m	sired position	*	Set cable		10 m h to desired p	osition *
E2C-AK4A		or odbio longti	1 SWILOIT TO GO	oned position	•	COT CADIO	o longal swite	ii to dosilod p	

Note: The standard cable length is 3 m. Models with 5-m or 10-m are manufactured upon order.

#### **Heat-resistant Models**


Sensor	E2C-X1R5AH	E2C-X2AH	E2C-X5AH			
Amplifier Units	EZO-ATROAH	EZO-AZAN				
E2C-JC4CH						
E2C-JC4DH	Set 3 m/5 m cable length switch to desired position.					
E2C-JC4EH						

Note: The standard cable length is 3 m. Models with 5-m are manufactured upon order.


## Self-diagnostic Function

The self-diagnostic output transistor will turn ON in the following cases. (The output will turn ON for any of these conditions individually.) (1) Sensor open circuit: Transistor will turn ON the instance there is an open circuit for the Sensor (including the cable).

#### Sensor Open Circuit



#### **Sensor Connected**




Note: When the E2C-X2A Sensor is used, 93% is 96% and 107% is 104%.

\* The self-diagnostic output may turn ON if the sensing objects moves a low speed. In actual application, include an ON-delay timer circuit or other suitable measure.

- (2) Detection: The output will turn ON if a sensing object is within 93% to 100% of the sensing distance continuously for 0.3 s or longer (e.g., for sensing object position offset).
- (3) No detection: The output will turn ON if a sensing object is within 100% to 107% of the sensing distance continuously for 0.3 s or longer (e.g., when background is influencing detection).

## **Indicators**


- The detection indicator lights when a sensing object approaches the sensing distance to indicate that a sensing object has been detected.
- The stability indicator lights when the sensing object approaches within 93% of the sensing distance or moves away from 107% of the sensing distance to indicate a stable sensing or non-sensing condition.




<sup>\*</sup> Refer to page 14 for the operation of cable length switching.

## **Sensing Area**







## E2C-X1A/-C1A




#### E2C-X1R5A




## E2C-X2A




#### E2C-X5A




## E2C-X10A




E2C-C20MA




#### E2C-X1R5AH + E2C-JC4CH



E2C-X2AH + E2C-JC4DH




#### E2C-X5AH + E2C-JC4EH




## Influence of Sensing Object Size and Material


#### E2C-CR8□




#### E2C-X1A/-C1A




#### E2C-X1R5A




#### E2C-X2A




## E2C-X5A




**E2C-X10A** 




E2C-C20MA




## E2C-X1R5AH + E2C-JC4CH




E2C-X2AH + E2C-JC4DH




E2C-X5AH + E2C-JC4EH



# **I/O Circuit Diagrams**





# **Connections between Amplifier Unit and Sensor**



## **Load Connections**

Model Load	E2C-JC4A, E2C-JC4⊟H
DC load • Relay • Solenoid  Current-sinking load • Programmable Controller • Sensor Controller	Brown Black Blue
Voltage load (logic circuit)	Brown Black 4.7 k V To next stage OV Interface circuits Logic circuit







The E2C-AK4A supports relay and transistor/photocoupler outputs, and the E2C-AM4A supports both NPN and PNP open-collector output. They can be connected to a wide variety of load types and power polarities.

# **Nomenclature and Timing Charts**

### **Amplifier Units**





#### E2C-A□4A The detection indicator (red) indicates the detection status. OMRON E2C-AK4A PROXIMITY SWITCH AMPLIFIER (AC) (Object detected: ON, No object detected: OFF) Operation switch Stability indicator (green) Indicates that the detection or non-detection level is stable. (Stable: ON, Unstable: OFF) Changes NO/NC **Timing Chart** Cable length compensation Operation switch switch\* Sensing distance adjustment Present Sensing object Not present (4-turn potentiometer) ON Relay output Differential travel adjuster (transistor output) OFF ON Detection indicator (red)

OFF

## **Amplifier Unit Switch Settings**

Applicable Sensors	Cable length	0 to 1 m	1 to 2 m	2 to 3 m	3 to 4 m	4 to 5 m	5 to 6 m	6 to 7 m	7 to 8 m	8 to 9 m	9 to 10 m
E2C-CR8A E2C-CR8B E2C-X1A E2C-C1A E2C-X1R5A		A B C D	A B C D	A B C D	A B C D	A B C D					
E2C-X2A E2C-X5A E2C-X10A E2C-C20MA		A B C D	A B C D	A B C D	A B C D	A B C D	A B C D	A B C D	A B C D	A B C D	A B C D

Note: 1. Mutual Interference Prevention: When mounting Sensors with the same diameter and cable length in parallel, set the DIP switch to modes that differ by 1 m in cable length. Specifications, however, may not be sufficiently met, so always check operation before actual application. This method cannot be used for the E2C-C20MA.

<sup>\*</sup> Cable Length Compensation Switching
Set this switch to the proper setting depending on whether the standard cable length is being used or the cable has been cut shorter.

<sup>2.</sup> When using the E2C-CR5B + E2C-AM4A (or AK4A), set all the pins on the Amplifier Unit DIP switch to the left.

# **Safety Precautions**

## Refer to Warranty and Limitations of Liability.



This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purposes.




#### **Precautions for Correct Use**

Do not use the Encoder under ambient conditions that exceed the ratings.

#### Design

## **Influence of Surrounding Metal**

When mounting the Sensor within a metal panel, ensure that the clearances given in the following table are maintained. Failure to maintain these distances may cause deterioration in the performance of the Sensor.



#### Influence of Surrounding Metal

(Unit: mm)


Model	Distance	ı	d	D	m
E2C-CR8			(3.5)		2.4
E2C-X1A			(5)		3
E2C-C1A			(5.4)		3
E2C-X1R5	<b>A(H)</b>	0	(8)	0	4.5
E2C-X2A(H			(12)		6
E2C-X5A(H	l)		(18)		15
E2C-X10A			(30)		30
E2C-C20M	A	25	120	40	60

Note: Values in parentheses for diameter d are the outer diameters of Shielded Models

## **Mutual Interference**

When installing Sensors face-to-face or side-by-side, ensure that the minimum distances given in the following table are maintained. Mutual interference can be prevented by using the cable length compensation switch, but doing so will also change coil characteristics. Specifications such as temperature specifications and sensing distance, may not be sufficiently met, so always check operation before actual application.

This method cannot be used for the E2C-G□4A, E2C-JC4A, E2C-C20MA.



#### Mutual Interference (Unit: mm)

Model	Distance	Α	В
E2C-CR8			
E2C-X1A		20	15
E2C-C1A		20	13
E2C-X1R5A(	H)		
E2C-X2A(H)		30	20
E2C-X5A(H)		50	35
E2C-X10A		100	70
E2C-C20MA		300	200

Note: The above values are for a differential travel setting of 5%.

#### Mounting


 Do not use excessive force when tightening the nuts on the E2C-X and E2C-C20MA. A washer must be used with the nut.



Model	Torque
E2C-X1A	0.98 N·m
E2C-X1R5A(H)	2.0 N·m
E2C-X2A(H)	5.9 N·m
E2C-X5A(H)	15 N·m
E2C-X10A	39 N·m
E2C-C20MA	15 N·m

Note: The above leeways in tighten torque assume that a toothed washer is being used.

Mounting Unthreaded Cylindrical Models
 When using a set screw, tighten it to a torque of 0.2 N⋅m max.



Y92E-F3R5 Mounting Bracket (for 3.5 dia.) (Order Separately)



The Y92E-F5R4 (for 5.4 dia.) is also sold separately.


## Mounting

#### **Mounting the Amplifier Unit**

#### E2C-JC4A


## **Lengthwise Mounting**

- (1)Secure the Mounting Bracket with the enclosed M3 screws.
- (2)Loosen the M2.6 cover screw and remove the cover.
- (3)Slide the protrusion on the Amplifier Unit into the hole on the Mounting Bracket.
- (4)Using the M3 mounting screw inside the Amplifier Unit, secure the Amplifier Unit to the mounting base.
- (5)Secure the cover to the case.



## Mounting to the Side

- (1)Loosen the M2.6 cover screw and remove the cover. Loosen the M2.6 cover screw and remove the cover, and remove the M3 screw.
- (2)Attached the enclosed M3 screw to the cover and secure the cover to the case
- (3)Secure the Amplifier Unit with M3 screws from the side. You must provide these screws.




After completing adjustments, attach the enclosed caution label over the adjustment holes to prevent adjustment mistakes.



#### E2C-A□4A


## Using P2CF-11, P2CF-08

When aligning the Amplifier Unit vertically with the Socket, consider the space required for the hooks and allow a leeway of about 20 mm above and below the Amplifier Unit.




#### Mounting Embedded in a Panel

(1)When using the Y92F-30 Embedded Mounting Adapter, insert the Amplifier Unit into a square hold in the panel, attach the Adapter from the back and press in to reduce the gap with the panel. Then secure the Adapter with the screws.




(2)When using the Y92F-70 or Y92F-71 Embedded Mounting Adapter, just press the Amplifier into a square hole in the panel. If the panel coating is too thick and the hooks do not lock in place, spread the hooks from the back by pushing in the directions of the arrows




Insert the Sensor and then spread the hooks.

## **Removing the Amplifier Unit**

 When the Amplifier Unit is mounted using the Y92F-30, loosen the screws on the adapter, spread the hooks at the top and bottom, and remove the Adapter.



Using Y92F-70, Y92F-71
 Press in on the hooks with your thumb and forefinger and press forward on the Amplifier Unit.



## Wiring

## **Self-diagnostic Output**

When not using the self-diagnostic output, connect the orange wire to 0 V or cut it and wrap it with insulation tape so that it does not come into contact with other terminals.

#### Miscellaneous


The sensor does not have a water-resistant structure. Do not use it where it would be subjected to water or water vapor.

## **Main Units**

Sensor









\*E2C-CR8B: Diameter is 3.8.

## E2C-X1A




#### E2C-C1A




### E2C-X1R5A E2C-X1R5AH\*







### E2C-X2A E2C-X2AH\*



## E2C-X5A E2C-X5AH\*





## **E2C-X10A**



#### E2C-C20MA







## **Mounting Hole Dimensions**




Model	F (mm)	Model	F (mm)	Model	F (mm)	
E2C-CR8A	3.7-dia. +0.3	E2C-X1A	5.4-dia. +0.5	E2C-X5A	18.5-dia. +0.5	
E2C-CR8B	4.0-dia. +0.3	E2C-X1R5A	8.5-dia. +0.5	E2C-X10A	30.5-dia. +0.5	
E2C-C1A	5.7-dia. +0.3	E2C-X2A	12.5-dia. +0.5	E2C-C20MA	18.5-dia. +0.5	

## **Amplifier Units**

### E2C-GE4A E2C-GF4A







\* After completing adjustments, attach the caution label to prevent adjustment mistakes.

#### **Applicable Sockets** (Sold Separately)


- PYFZ-08
- PYF08

Hold-down Clip

• PYC-A1

## E2C-AK4A (11-pin) E2C-AM4A (8-pin)






## Applicable Sockets (Sold Separately)

For E2C-AK4A (11-pin)

- P2CF-11
- P3GA-11

For E2C-AM4A (8-pin)


- P2CF-08
- P3G-08



#### E2C-JC4AP


# 40±0.2 Mounting Bracket Installation

Detection indicator (red)



Timer switch

- \*1. After completing adjustments, attach the caution label to prevent adjustment mistakes.
  \*2. Not required when mounting to DIN Track.
  \*3: 4.5-dia. vinyl-insulated round cable with 4 conductors (Conductor cross section: 0.2 mm², Insulator diameter: 1.2 mm), Standard length: 2 m



- \*1. After completing adjustments, attach the caution label to prevent adjustment mistakes
  \*2. Not required when mounting to DIN Track.
  \*3. 4-dia. vinyl-insulated round cable with 3 conductors (Conductor cross section: 0.2 mm², insulator diameter: 1.2 mm), Standard length: 2 m
  The cable can be extended up to 200 m (separate metal conduit).


## **Accessories (Order Separately)**

## **Mounting Bracket**


Mounting Bracket (for Unthreaded Cylindrical Models) Y92E-F3R5 (for 3.5 dia.) Y92E--F5R4 (for 5.4 dia.)



#### Y92E-F3R5





#### Y92E-F5R4




#### **Front Connection Sockets**








# Terminal Arrangement and Internal Connections (Top View)




#### **Mounting Hole Dimensions**




Note: Track mounting is also possible.


## P2CF-08








## **Mounting Hole Dimensions**




Note: Track mounting is also possible.


# P2CF-11



#### Terminal Arrangement and Internal Connections (Top View)



## **Mounting Hole Dimensions**





Note: Track mounting is also possible.

## **Back Connection Sockets**

## P3G-08









Terminal Arrangement and Internal Connections (Bottom View)



P3GA-11








Terminal Arrangement and Internal Connections (Bottom View)



PY08








Terminal Arrangement and Internal Connections (Bottom View)




Mounting Holes and PCB Cutout Dimensions




## Embedded Mounting Adapter (for E2C-AK4A/E2C-AM4A Amplifier Unit)

## Y92F-30







# Mounting Hole Dimensions R: 0.5 max. 45+0.5 → |


 $45 + {}^{0.5}_{0}$ 


Note 1. Suitable mounting panel thickness: 1 to 5 mm

Note 2. Check the direction of the Adapter, which depends on whether Amplifier Units are arranged vertically or horizontally.


## Y92F-70








## **Mounting Hole Dimensions**




Note: Suitable mounting panel thickness: 1 to 3.2 mm


## Y92F-71







## Mounting Hole Dimensions



Note: Suitable mounting panel thickness: 1 to 3.2 mm

## Terms and Conditions Agreement

#### Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

#### Warranties.

- (a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.
- (b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE

PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See <a href="http://www.omron.com/global/">http://www.omron.com/global/</a> or contact your Omron representative for published information.

#### Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

### Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

### Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

#### Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

#### Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions. Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

2024.11

In the interest of product improvement, specifications are subject to change without notice.