
PCB terminal block; operating lever; 4 mm²; Pin spacing 7.5 mm; 2-pole;

Push-in CAGE CLAMP®

www.wago.com/2604-1302







 $L = (pole no. - 1) \times pin spacing + 7.4 mm$

Item description

- PCB terminal blocks with lever-actuated Push-in CAGE CLAMP® connection
- Push-in termination of solid and ferruled conductors
- Intuitive and tool-free operation
- Several clamping units can be held open simultaneously convenient for terminating multi-core cables
- Testing can be performed both parallel and perpendicular to conductor entry

Other versions (or variants) can be requested from WAGO Sales or configured at https://configurator.wago.com/. Direct marking, Other pole numbers

www.wago.com/2604-1302



Data

Electrical data

630 V
6 kV
630 V
6 kV
1000 V
6 kV
32 A
(III / 2) ≙ Overvoltage category III / Pollution degree 2
300 V
20 A
300 V
20 A
600 V
5 A

Connection data

ating lever . 4 mm ² / 24 12 AWG . 4 mm ² / 24 12 AWG
4 mm² / 24 12 AWG
-
2.5 mm²
2.5 mm²
1.5 mm²
1 mm / 0.35 0.43 lnch

www.wago.com/2604-1302



Geometrical Data

Pin spacing	7.5 mm (0.295 in)
Width	14.9 mm / 0.587 lnch
Height	20.7 mm / 0.815 lnch
Height from the surface	16.7 mm / 0.657 lnch
Depth	19.2 mm / 0.756 lnch
Solder pin length	4 mm
Solder pin dimensions	0.8 x 1 mm
Drilled hole diameter (tolerance)	1.3 ^(+ 0.1) mm

PCB contact

PCB contact	THT
Solder pin arrangement	over the entire terminal strip, in line
Number of solder pins per potential	2

Material Data

Color	gray
Material group	1
Insulating material	Polyamide 66 (PA 66)
Flammability class per UL94	V0
Clamping spring material	Chrome nickel spring steel (CrNi)
Contact material	Electrolytic copper (Ecu)
Contact plating	tin-plated
Actuating element color	orange
Weight	3.667 g

Environmental Requirements

Limit temperature range -60 105 °C

Commercial data

Packaging type	BOX
Country of rigin	DE
GTIN	4055143564403
Customs Tariff No.	85369010000

www.wago.com/2604-1302



Country specific Approvals

Logo	Approval	Certificate name	
	СВ	NL-47057	
	DEKRA Certification B.V.		
	CSA	70117145	
GP	DEKRA Certification B.V.		

UL-Approvals

Logo	Approval	Certificate name	
c SN us	cURus Underwriters Laboratories Inc.	E45172 sec. 71	

Subject to changes.

WAGO Kontakttechnik GmbH & Co. KG Hansastr. 27 32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com