

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Primary-switched QUINT POWER power supply for DIN rail mounting with SFB (Selective Fuse Breaking) Technology, input: 3-phase, output: 24 V DC/5 A

Product Description

QUINT POWER power supplies with maximum functionality

QUINT POWER circuit breakers magnetically and therefore quickly trip at six times the nominal current, for selective and therefore cost-effective system protection. The high level of system availability is additionally ensured, thanks to preventive function monitoring, as it reports critical operating states before errors occur.

Reliable starting of heavy loads takes place via the static power reserve POWER BOOST. Thanks to the adjustable voltage, all ranges between 5 V DC ... 56 V DC are covered.

Product Features

- High level of system availability even in the event of permanent phase failure
- Reliable starting of difficult loads
- Preventive function monitoring



Key Commercial Data

Packing unit	1 pc
Weight per Piece (excluding packing)	1038.0 g
Custom tariff number	85044030
Country of origin	Thailand

Technical data

Dimensions

Width	40 mm
Height	130 mm
Depth	125 mm
Width with alternative assembly	122 mm
Height with alternative assembly	130 mm



Technical data

Dimensions

Depth with alternative assembly	43 mm

Ambient conditions

Degree of protection	IP20
Ambient temperature (operation)	-25 °C 70 °C (> 60 °C Derating: 2,5 %/K)
Ambient temperature (storage/transport)	-40 °C 85 °C
Max. permissible relative humidity (operation)	≤ 95 % (at 25 °C, non-condensing)
Noise immunity	EN 61000-6-2:2005
Maximum altitude	5000 m

Input data

_ •	
Nominal input voltage range	3x 400 V AC 500 V AC
Input voltage range	3x 320 V AC 575 V AC
	2x 360 V AC 575 V AC
	450 V DC 800 V DC
AC frequency range	45 Hz 65 Hz
Frequency range DC	0 Hz
Discharge current to PE	< 3.5 mA
Current consumption	3x 0.8 A (400 V AC)
	3x 0.7 A (500 V AC)
	0.2 A (600 V DC)
Inrush surge current	< 15 A (typical)
Power failure bypass	> 20 ms (400 V AC)
	> 30 ms (500 V AC)
Choice of suitable circuit breakers	6 A 16 A (AC: Characteristics B, C, D, K)
Type of protection	Transient surge protection
Protective circuit/component	Varistor, gas-filled surge arrester

Output data

Nominal output voltage	24 V DC ±1 %
Setting range of the output voltage (U _{Set})	18 V DC 29.5 V DC (> 24 V DC, constant capacity restricted)
Nominal output current (I _N)	5 A (-25°C 60°C, U _{OUT} = 24 V DC)
POWER BOOST (I _{Boost})	7.5 A (-25°C 40°C permanent, U _{OUT} = 24 V DC)
Selective Fuse Breaking (I _{SFB})	30 A (12 ms)
Derating	60 °C 70 °C (2.5%/K)
Connection in parallel	Yes, for redundancy and increased capacity
Connection in series	Yes
Residual ripple	< 20 mV _{PP} (with nominal values)
Output power	120 W



Technical data

Output data

Typical response time	< 0.06 s
Peak switching voltages nominal load	< 20 mV _{PP} (at nominal values, 20 MHz)
Maximum power dissipation in no-load condition	4 W
Power loss nominal load max.	14 W

General

Net weight	0.7 kg
Operating voltage display	Green LED
Efficiency	> 89 % (at 400 V AC and nominal values)
Insulation voltage input/output	4 kV AC (type test)
	2 kV AC (routine test)
Protection class	1
MTBF (IEC 61709, SN 29500)	> 1290000 h (25 °C)
	> 680000 h (40°C)
	> 290000 h (60°C)
Mounting position	horizontal DIN rail NS 35, EN 60715
Assembly instructions	Alignable: 5 mm horizontally, 15 mm next to active components, 50 mm vertically

Connection data, input

Connection method	Pluggable screw connection
Conductor cross section solid min.	0.2 mm ²
Conductor cross section solid max.	2.5 mm ²
Conductor cross section flexible min.	0.2 mm²
Conductor cross section flexible max.	2.5 mm²
Conductor cross section AWG min.	20
Conductor cross section AWG max.	12
Stripping length	7 mm
Screw thread	M3

Connection data, output

Connection method	Pluggable screw connection
Conductor cross section solid min.	0.2 mm²
Conductor cross section solid max.	2.5 mm²
Conductor cross section flexible min.	0.2 mm²
Conductor cross section flexible max.	2.5 mm²
Conductor cross section AWG min.	20
Conductor cross section AWG max.	12
Stripping length	7 mm



Technical data

Connection data, output

Screw thread	M3
Connection data for signaling	
Conductor cross section solid min.	0.2 mm²
Conductor cross section solid max.	2.5 mm²
Conductor cross section flexible min.	0.2 mm²
Conductor cross section flexible max.	2.5 mm²
Conductor cross section AWG min.	20
Conductor cross section AWG max.	12
Screw thread	M3

Standards and Regulations

Shock 30g in each direction, according to IEC 60068-2-27 Noise immunity EN 61000-6-2:2005 Connection in acc. with standard CSA Standards/regulations EN 61000-4-3 EN 61000-4-3 EN 61000-4-4 EN 61000-4-6 Standard - Electrical equipment of machines EN 60204-1 Standard - Electrical safety IEC 60950-1/VDE 0805 (SELV) Standard - Electrical equipment for use in electrical power installations and their assembly into electrical power installations Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safety extra-low remarks, basic requirements for protective separation in electrical equipment Standard - Limitation of mains harmonic currents EN 50178 Standard - Limitation of mains harmonic currents EN 61000-3-2 Standard - Approval for medical use IEC 60061-1, 2 x MOOP Shipbuilding approval Germanischer Lloyd (EMC 2), ABS, LR, RINA, NK, DNV, BV UL approvals UL - UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips SEMI F47-0706 Compliance Certificate	Ctartaarab arta ragalatione	
Noise immunity EN 61000-6-2:2005 Connection in acc. with standard CSA Standards/regulations EN 61000-4-3 EN 61000-4-6 Standard - Electrical equipment of machines EN 60204-1 Standard - Electrical equipment for use in electrical power installations and their assembly into electrical power installations and their assembly into electrical power installations Standard - Safety extra-low voltage EC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safe isolation DIN VDE 0100-410 Standard - Protection against shock currents, basic requirements for protective separation in electrical equipment Standard - Limitation of mains harmonic currents EN 61000-3-2 Standard - Approval for medical use EC 60601-1, 2 x MOOP Shipbuilding approval UL approvals UL 1:sted UL 508 UL'C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12-10. Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips SEMI F47-0706 Compliance Certificate	Electromagnetic compatibility	Conformance with EMC Directive 2004/108/EC
Connection in acc. with standard CSA Standards/regulations EN 61000-4-3 EN 61000-4-4 EN 61000-4-6 Standard - Electrical equipment of machines EN 60204-1 Standard - Electrical safety IEC 60950-1/VDE 0805 (SELV) Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Protection against shock currents, basic requirements for protective separation in electrical equipment Standard - Limitation of mains harmonic currents EN 50178 Standard - Equipment safety GS (tested safety) Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval UL Listed UL 508 UL/C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips SEMI F47-0706 Compliance Certificate	Shock	30g in each direction, according to IEC 60068-2-27
Standards/regulations EN 61000-4-3 EN 61000-4-6 Standard – Electrical equipment of machines EN 60004-1 Standard – Electrical safety EN 60204-1 Standard – Electronic equipment for use in electrical power installations and their assembly into electrical power installations Standard – Safety extra-low voltage EN 50178/VDE 0160 (PELV) Standard – Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard – Safet isolation DIN VDE 0100-410 EN 50178 Standard – Imitation of mains harmonic currents, basic requirements for protective separation in electrical equipment Standard – Limitation of mains harmonic currents EN 61000-3-2 Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval UL Listed UL 508 UL/C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) < 15 Hz, amplitude ±2.5 mm (according to IEC 60068-2-6) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips SEMI F47-0706 Compliance Certificate	Noise immunity	EN 61000-6-2:2005
EN 61000-4-4 EN 61000-4-6 Standard – Electrical equipment of machines EN 60204-1 Standard - Electrical safety IEC 60950-1/VDE 0805 (SELV) Standard – Electronic equipment for use in electrical power installations and their assembly into electrical power installations and their assembly into electrical power installations Standard – Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard – Safe isolation DIN VDE 0100-410 EN 50178 Standard – Protection against shock currents, basic requirements for protective separation in electrical equipment EN 61000-3-2 Standard – Limitation of mains harmonic currents EN 61000-3-2 Standard – Equipment safety GS (tested safety) Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval UL Listed UL 508 UL/C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips EN 61000-4-1 EN 60204-1 EN 50178 EN 61000-3-2 SEMI F47-0706 Compliance Certificate	Connection in acc. with standard	CSA
EN 61000-4-6 Standard – Electrical equipment of machines EN 60204-1 Standard – Electrical safety EC 60950-1/VDE 0805 (SELV) Standard – Electronic equipment for use in electrical power installations and their assembly into electron (PELV) EN 50178 EN 6005-1 (SELV) and EN 60204-1 (PELV) EN 50178 EN 61000-3-2 Standard - Portection against end of experiments for protective assertion in electrical equipment EN 50178 EN 6000-3-2 Standard - Portection against end of experiments for electron-10 (EN 000-3-2) EN 50178 EN 6000-3-2 Standard - Portection against end of experiments for electron-10 (EN 000-3-2) EN 50178 EN 50178 EN 6000-3-1 EN 50178 EN 6000-3-2 Standard - Petervy EN 6000-3-2 Stand	Standards/regulations	EN 61000-4-3
Standard – Electrical equipment of machines EN 60204-1 Standard – Electrical safety IEC 60950-1/VDE 0805 (SELV) Standard – Electronic equipment for use in electrical power installations and their assembly into electrical power installations and their assembly into electrical power installations Standard – Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Protection against shock currents, basic requirements for protective separation in electrical equipment EN 50178 Standard – Limitation of mains harmonic currents EN 61000-3-2 Standard - Equipment safety GS (tested safety) Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval UL approvals UL Listed UL 508 UL/C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips SEMI F47-0706 Compliance Certificate		EN 61000-4-4
Standard - Electrical safety Standard - Electronic equipment for use in electrical power installations and their assembly into electrical power installations Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safe isolation DIN VDE 0100-410 Standard - Protection against shock currents, basic requirements for protective separation in electrical equipment Standard - Limitation of mains harmonic currents EN 61000-3-2 Standard - Equipment safety Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval Germanischer Lloyd (EMC 2), ABS, LR, RINA, NK, DNV, BV UL approvals UL/C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) < 15 Hz, amplitude ±2.5 mm (according to IEC 60068-2-6) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips SEMI F47-0706 Compliance Certificate		EN 61000-4-6
Standard – Electronic equipment for use in electrical power installations and their assembly into electrical power installations Standard – Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard – Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard – Protection against shock currents, basic requirements for protective separation in electrical equipment Standard – Limitation of mains harmonic currents EN 61000-3-2 Standard - Equipment safety Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval Germanischer Lloyd (EMC 2), ABS, LR, RINA, NK, DNV, BV UL approvals UL Listed UL 508 UL/C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) < 15 Hz, amplitude ±2.5 mm (according to IEC 60068-2-6) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips SEMI F47-0706 Compliance Certificate	Standard – Electrical equipment of machines	EN 60204-1
and their assembly into electrical power installations Standard - Safety extra-low voltage IEC 60950-1 (SELV) and EN 60204-1 (PELV) Standard - Safe isolation DIN VDE 0100-410 Standard - Protection against shock currents, basic requirements for protective separation in electrical equipment Standard - Limitation of mains harmonic currents EN 61000-3-2 Standard - Equipment safety Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval UL approvals ULC-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips IEC 60950-1 (SELV) and EN 60204-1 (PELV) IN ORD (SELV) IEC 60950-1 (SELV) and EN 60204-1 (PELV) IN ORD (SELV) IEC 60950-1 (SELV) and EN 60204-1 (PELV) IEC 60950-1 (SELV) and EN 60204-1 (PELV) IEC 60950-1 (SELV) and EN 60204-1 (PELV) IEC 60950-1 (SELV) IEC 60950-1 (SELV) and EN 60204-1 (PELV) IEC 60950-1 (SELV) and EN 60204-1 (PELV) IEC 60950-1 (SELV) IEC 60950-1 (SELV) IEC 60061-1, 2 x MOOP Standard - Approval Centre of the semiconductor industry with regard to mains voltage dips	Standard - Electrical safety	IEC 60950-1/VDE 0805 (SELV)
Standard - Safe isolation Standard - Protection against shock currents, basic requirements for protective separation in electrical equipment Standard - Limitation of mains harmonic currents EN 61000-3-2 Standard - Equipment safety Standard - Approval for medical use IEC 60601-1, 2 x MOOP Shipbuilding approval UL approvals UL Listed UL 508 UL/C-UL Recognized UL 60950-1 (3-wire + PE, star net) UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation) Low Voltage Directive Approval - requirement of the semiconductor industry with regard to mains voltage dips Standard - Safe isolation DIN VDE 0100-410 EN 50178 EN 61000-3-2 EN 61000-3-2 IEC 60601-1, 2 x MOOP Germanischer Lloyd (EMC 2), ABS, LR, RINA, NK, DNV, BV UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D (Hazardous Location) Vibration (operation)		



Technical data

Standards and Regulations

Rail applications	EN 50121-4
The state of	

Classifications

eCl@ss

eCl@ss 4.0	27040702
eCl@ss 4.1	27040702
eCl@ss 5.0	27049002
eCl@ss 5.1	27049002
eCl@ss 6.0	27049002
eCl@ss 7.0	27049002
eCl@ss 8.0	27049002
eCl@ss 9.0	27040701

ETIM

ETIM 2.0	EC001039
ETIM 3.0	EC001039
ETIM 4.0	EC000599
ETIM 5.0	EC002540

UNSPSC

UNSPSC 6.01	30211502
UNSPSC 7.0901	39121004
UNSPSC 11	39121004
UNSPSC 12.01	39121004
UNSPSC 13.2	39121004

Approvals

Approvals

Approvals

CSA / UL Recognized / UL Listed / cUL Recognized / LR / GL / BV / ABS / NK / RINA / IECEE CB Scheme / SEMI F47 / IECEE CB Scheme / EAC / CSA / EAC / GL / BV / NK / RINA / cULus Recognized

Ex Approvals

UL Listed / cUL Listed / cULus Listed




Approvals	
Approvals submitted	
Approval details	
CSA 10	
UL Recognized SN	
UL Listed (II)	
cUL Recognized	
LR	
GL	
BV	
ABS	
NK	
Towns	
RINA	
IECEE CB Scheme CB	
SEMI F47	
LOCIVILE47	



Approvals

CEE CB Scheme CB	
AC	
SA SA	
AC	
<	
NA NA	
JLus Recognized C \$ 10 us	

Drawings



Phoenix Contact 2016 © - all rights reserved http://www.phoenixcontact.com