

COMPACT splicing connector; for solid conductors; max. 2.5 mm<sup>2</sup>; 8-conductor; transparent housing; light gray cover; Surrounding air temperature: max 60°C (T60); 2,50 mm<sup>2</sup>; transparent



www.wago.com/2273-208





### Item description

Advantages:

- Convenient wiring via an extremely compact design
- Push-in termination of up to eight solid conductors
- Cross-section range: 0.5 ... 2.5 mm²
- Any combination of conductor sizes is possible
- PUSH WIRE® connection terminates solid ("s") copper conductors

#### Note:

## **Terminating Aluminum Conductors**

WAGO spring clamp terminal blocks are suitable for solid aluminum conductors up to 4 mm<sup>2</sup>/12 AWG if WAGO "Alu-Plus" Contact Paste is used for termination.

"Alu-Plus" Contact Paste Advantages:

Subject to changes. Please also observe the further product documentation!

WAGO Kontakttechnik GmbH & Co. KG Hansastr. 27

32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com Do you have any questions about our products? We are always happy to take your call at +49 (571) 887-44222.

www.wago.com/2273-208



- Automatically destroys the oxide film during clamping.
- Prevents fresh oxidation at the clamping point.
- Prevents electrolytic corrosion between aluminum and copper conductors (in the same terminal block).
- Provides long-term protection against corrosion.

For spring clamp connections with PUSH WIRE® connection technology, **WAGO** recommends that the aluminum conductor first be cleaned and then immediately inserted into the clamping unit filled with "Alu-Plus" contact paste.

It is also possible to apply WAGO "Alu-Plus" additionally on the whole surface of the aluminum conductor before termination.

Please note that the nominal currents must be adapted to the reduced conductivity of the aluminum conductors::

 $2.5 \text{ mm}^2 = 16 \text{ A}$ 

4 mm<sup>2</sup> = 22 A

## Safety information 1:

in grounded power lines

## Data

### Electrical data

## Ratings per IEC/EN 60664-1

Ratings per	IEC/EN 60664-1
Nominal voltage (II/2)	450 V
Rated surge voltage (II/2)	4 kV
Rated current	24 A
Legend (ratings)	(II / 2) ≙ Overvoltage category II / Pollution degree 2

## Connection data

Connection technology	PUSH WIRE®
Actuation type	Push-in
Connectable conductor materials	Copper Aluminum
Solid conductor	0,5 2,5 mm² / 20 16 AWG
Strip length	11 mm / 0.43 inch
Total number of connection points	8
Total number of potentials	1
Wiring type	Side-entry wiring

Subject to changes. Please also observe the further product documentation!

WAGO Kontakttechnik GmbH & Co. KG

Hansastr. 27 32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com Do you have any questions about our products?

We are always happy to take your call at +49 (571) 887-44222.



## **Geometrical Data**

Width	18 mm / 0.709 inch
Height	10,4 mm / 0.409 inch
Depth	16,7 mm / 0.657 inch

#### **Material Data**

Color	transparent
Cover color	light gray
Flammability class per UL94	V2
Fire load	0.039 MJ
Weight	2.2 g

# **Environmental Requirements**

Surrounding air temperature (operation)	60 60 °C
Continuous operating temperature	105 105 ℃
Temperature marking per EN 60998	T60

### Commercial data

Product Group	7 (Push Wire Conn.)
Packaging type	BOX
Country of origin	DE
GTIN	4050821027881
Customs tariff number	85369010000

# Approvals / Certificates

## **Country specific Approvals**

_			
	VDE	EN 60998	40029794
Logo	Approval	Additional Approval Text	name
			Certificate



VDE Prüf- und Zertifizierungsinstitut

## Ship Approvals

	ABS	-	15-
Logo	Approval	Additional Approval Text	name
			Certificate

Subject to changes. Please also observe the further product documentation!

WAGO Kontakttechnik GmbH & Co. KG

Hansastr. 27 32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com Do you have any questions about our products?

We are always happy to take your call at +49 (571) 887-44222.

www.wago.com/2273-208





American Bureau of Shipping

HG1419918-PDA



**DNV GL** Det Norske Veritas, Germanischer Lloyd EN 60998

TAE000015T

EN 60998 04/20013

(E8)



Lloyds Register

LR

# Counterpart

## Compatible products

# Mounting adapter

Item no.: 2273-500

Mounting carrier; for single- and double-row con.; 2273 Series; for DIN-35 rail mounting/screw

www.wago.com/2273-500

mounting; orange



General accessories

Item no.: 249-130

Syringe; Contents: 20 ml Alu-Plus contact paste

www.wago.com/249-130

## **Downloads**

## **Documentation**

## **Bid Text**

2273-208 doc - Datei	May 17, 2017	doc 25.1 kB	Download
2273-208 GAEB X81 - Datei	Feb 19, 2019	xml 3.3 kB	Download

## CAD/CAE-Data

### **CAD** data

2D/3D Models 2273-208

Subject to changes. Please also observe the further product documentation!

WAGO Kontakttechnik GmbH & Co. KG

Hansastr. 27 32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com Do you have any questions about our products?


We are always happy to take your call at +49 (571) 887-44222.



	URL	Download
CAE data		
EPLAN Data Portal 2273-208	URL	Download
WSCAD Universe 2273-208	URL	Download
ZUKEN Portal 2273-208	URL	Download

#### **Installation Notes**

#### Conductor termination



Strip solid conductor to 11 mm / 0.43 inch (see marking).



The transparent housing shows if conductors are fully inserted; within the colored base, a clear port shows if the conductor's strip length is correct.



Termination: Insert stripped solid conductor until it hits backstop.

Conductors are correctly stripped if the clear port shows no bare conductor on the unprinted connector side. Picture shows center conductor with exceeded strip length.

 $\label{thm:continuity} \textbf{Subject to changes. Please also observe the further product documentation!}$ 

WAGO Kontakttechnik GmbH & Co. KG Hansastr. 27 32423 Minden

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com Do you have any questions about our products? We are always happy to take your call at +49 (571) 887-44222.

www.wago.com/2273-208





Removal: Hold conductor to be removed and twist alternately left and right while pulling the connector.

# Testing



Testing via test port opposite to conductor entry.

 $\label{thm:condition} \textbf{Subject to changes. Please also observe the further product documentation!}$ 

Phone: +49571 887-0 | Fax: +49571 887-169 Email: info.de@wago.com | Web: www.wago.com