

Testing tools
DIGI CHECK**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 16

D-32758 Detmold

Germany

Fon: +49 5231 14-0

Fax: +49 5231 14-292083

www.weidmueller.com



The main function of the voltage tester is to establish if voltage is present. A 2-pole voltage tester is the only approved testing instrument that fulfils the requirements of work protection regulations.

- with LCD-Display
- acc. to VDE standard,
- high peak voltage strength
- the right tester for every application

General ordering data

Delivery status	This article will no longer be available in the future.
Available until	2018-05-05
Type	DIGI CHECK
Order No.	9918850000
Version	2-pole voltage tester type 1153
GTIN (EAN)	4032248405732
Qty.	1 pc(s).
Alternative product	9918870000

Testing tools DIGI CHECK

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
www.weidmueller.com

Technical data

Dimensions and weights

Width	287 mm	Width (inches)	11.299 inch
Height	23 mm	Height (inches)	0.906 inch
Depth	68 mm	Depth (inches)	2.677 inch
Weight	290 g	Net weight	388 g

Environmental Product Compliance

REACH SVHC Lead 7439-92-1

Measuring and testing devices

AC voltage measuring range	5-690 V	Battery type	1.5 V type AAA battery
Continuity test	Yes - visual + acoustic	Display	LCD
Frequency measurement	Yes	Frequency range, max.	100 Hz
Frequency range, min.	0 Hz	Input resistance, voltage	≥ 300 kΩ
Insulation test	6 kV	Measuring range category	CATIV - 400V/ CAT III - 690V
Operating temperature, max.	45 °C	Operating temperature, min.	-15 °C
Peak voltage resistance	8 kV	Protection degree	IP65
Rated voltage, max.	690 V AC/DC	Rated voltage, min.	0.30 V
Tested and approved according to	EN/IEC 61010-1		

Classifications

ETIM 3.0	EC000494	ETIM 4.0	EC000494
ETIM 5.0	EC000494	ETIM 6.0	EC000494
UNSPSC	41-11-36-37	eClass 5.1	27-20-03-08
eClass 6.2	27-20-03-08	eClass 7.1	27-20-03-08
eClass 8.1	27-20-03-08	eClass 9.0	27-20-03-08
eClass 9.1	27-20-03-08		

Product information

Descriptive text technical data Buzzer included

Approvals

Approvals



ROHS Conform

Downloads

Approval/Certificate/Document of Conformity	9918850000_DECLARATION_OF_CONFORMITY.pdf
Brochure/Catalogue	CAT 6 TOOLS 15/16 EN
Product Change Notification	PCN-PW641010-20180410-00-A DE PCN-PW641010-20180410-00-A EN

Testing tools

DIGI CHECK

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 16
D-32758 Detmold
Germany
Fon: +49 5231 14-0
Fax: +49 5231 14-292083
www.weidmueller.com

Drawings

Example of use