DFS Series RCCB Earth Leakage Circuit Breakers

RCCB Series compact Earth Leakage Circuit Breakers detect and interrupt earth (ground) faults. They are VDE approved for the European system of protecting people, animals, equipment and property from dangerous line-to-ground and shock hazard currents.

US applications include groundfault protection of equipment (GFPE) using the 10mA and 30mA fault current ratings, especially when high distributed capacitance or other leakages cause excessive nuisance trips at lower fault currents. Applications for the 300mA and 500mA ratings are equipment protection and fire prevention, limiting the energy of a fault to less than the minimum ignition energy for many materials.

Type Designation

(a)



(a): 11 = 16A, 12 = 25A, 13 = 40A, 14 = 63A, 15 = 80A, 16 = 100A,

17 = 125A

(b): 2 = 10 mA, 4 = 30 mA,

6 = 300 mA, 7 = 500 mA

(c): 601 = 2 pole, 911 = 4 pole



DFS2





Maximum Rated Line Current	Fault Trip Current	Cat. No.	Supersedes	Fault Trip Current	Cat. No.	Supersedes
16A	10mA	09112601	RP2101			
25A 25A 25A	30mA 300mA	09124601 09126601	RP2203 RP2230	30mA 300mA 500mA	09124911 09126911 09127911	RP4203 RP4230 RP4250
40A 40A 40A	30mA 300mA	09134601 09136601	RP2303 RP2330	30mA 300mA 500mA	09134911 09136911 09137911	RP4303 RP4330 RP4350
63A 63A 63A	30mA 300mA 500mA	09144601 09146601	RP2403 RP2430	30mA 300mA 500mA	09144911 09146911 09147911	RP4403 RP4430 RP4450
80A 80A 80A				30mA 300mA 500mA	09154911 09156911 09157911	RP4503 RP4530 RP4550
100A 100A 100A				30mA 300mA 500mA	09164911 09166911 09167911	RP4603 RP4630 RP4650
125A 125A 125A				30mA 300mA 500mA	09174911 09176911 09177911	RP4703 RP4730 RP4750

Stock items are shown in BOLD.

Voltage Rating (maximum) Min Operating Voltage Bank of Test Circuit

Short Circuit Withstand Rating

No back-up fuse: Rated current (RC) 16/25/40A: 500A; RC 63/80A: 800A; RC 100A: 1000A; RC 125A-1250A. With back-up fuse: 10kA; Size of fuse: (2 pole version): RC 25/40/63: 100A; (4 pole version): RC 25/40/63A: 100A; RC 80/100/125A: 125A

Fault Trip Current Calibration

Typical Life Standard Pack and Weight **Terminal Size Acceptability**

Terminal Torque

FI trips are calibrated at less than fault trip current for ensured safety (Typical trip range between 66.6-83.3% fault trip current, e.g., typical trip at 20-25mA for fault RC of 30mA)

Fully functional after 5,000 operations to DIN/VDE 0664T10, IEC 61008-1 and 2000 additional fault current trips. 1/230g (0.6 lb.)

1/420-460g (0.9 lb.-1.0 lb.)

1.5-50mm² (16-1 AWG) 1.5-50mm² (16-1 AWG) 3Nm (26.5 lb.in.) 3Nm (26.5 lb.in.)


230V AC, 50Hz

150V

5 6


400Y/230V AC, 50Hz

200V



^b For voltage systems without a neutral conductor. Please use jumper from "1" or "3" to top "N" terminal. This will assure proper functioning of the "test"





DHI11 - Auxiliary Switches / Error Signal Switch




Contact Rating	Wire Size	Torque	Cat. No.	Supersedes	Circuit Diagram
6A / 230V AC 1A / 110V DC Std. Pk.: 1 Unit Weight: 45 Q Width: 9mm (.35		max. 0.8Nm (7lb.in.)	DHI11	RH11	14

Note: If the power system has a marked conductor, it must connect through the FI and not be grounded at any point downstream.

Altech Corp."

Dimensions in mm



Temperature Range

Environmental Information marked with "Snowflake" approval for -25°C to 40°C (-13°F to 104°F) ambient temperature. (Temperature effect on RC: for every 10°C temperature rise above 40°C decrease RC by 7%.)

Fluctuating Climate Conditions

According to IEC 60068-2-30: heat (25°C~55°C), relative humidity (93%~95%)

Electrical Shock Protection

Uninsulated electrically live parts within 30mm of the operating handle are "finger safe" (terminal screw heads) and uninsulated live parts within 100mm of the operating handle are "back-of-hand safe" (terminals).

Impact/Shock Protection

20g with impact force half-cycle sinusoidal and 20ms duration, 18 impacts total with 6 on each principal axis (3 impacts each face). FI is DIN Rail mounted during the test, and electrically loaded with 25% of Fault RC. Successful testing required no trip during the test, no damage and no loosened parts.

Vibration/Seismic Resistance

5g, at frequency of ≤80Hz, applied for 30 minutes along each of the three principal axes, plus 5 minutes of application at every established critical resonant frequency. FI is DIN Rail mounted during the test, and loaded with 25% Fault RC. To pass, the FI did not trip at 25% Fault RC, but did trip between each of the principal axis tests when the fault current was raised to 125% Fault RC, and there was no damage and no loosened parts. Suitable for machinery and mobile vehicle applications.

Protection Class

IP20; higher protection Class is dependent on housing.

Non-Sinusoidal Fault

The FI is tested and approval stamped for tripping sensitivity to non-sinusoidal fault currents, which become zero or almost zero within one cycle of the line frequency. Waveforms and allowed trip-current ranges are as follows:

- 1. AC Sinusoidal Fault 0.5-1.0 times Fault RC
- 2a. Pulsating DC Fault;
 - Positive and Negative Half-Waves 0.35-1.4 times Fault RC
- Phased Half-Wave, 90° 0.25-1.4 times Fault RC Phased Half-Wave, 135° - 0.11-1.4 times Fault RC
- Pulsating DC on 6mA
 DC (continuous) Base Max. 1.4 times Fault RC + 6mA

Insulation Category

At VDE rated voltage, suitable for Class C environments with relatively high dust and moisture levels and little HVAC control, e.g., industrial, commercial, agricultural; on machine tools, hoists, warehouse equipment, etc.; in boiler rooms, unheated storage, covered shipping/receiving, open workshops, etc.